

# Garden State Laboratories, Inc.

*Bacteriological and Chemical Testing*



Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 Email: info@gsllabs.com  
 Internet: www.gsllabs.com

Main Lab  
 410 Hillside Avenue  
 Hillside, New Jersey 07205  
 NJDEP Lab Cert. #20044

Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director  
 Jordan B. Klein, B.A., Exec. Vice President  
 Sharon Ercoliani, B.A., Laboratory Manager

**REPORT OF ANALYSIS**

Jersey Shore Lab  
 54 Main Street  
 Waretown, New Jersey 08758  
 NJDEP Lab Cert. #15037  
**REPORT # 400413002.0**

**TO: The ARC of Union County**  
 70 Diamond Road

**CLIENT # ARC13**  
**DATE SUBMITTED: 4/13/2020**

Springfield NJ 07081  
 ATT: Armando Jimenez

**SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE**

**SAMPLE ID: FIRST DRAW - FIELD BLANK**

**SAMPLE LOCATION: ARC KOHLER SCHOOL, 1137 GLOBE AVE., MOUNTAIN SIDE, NJ 07092**

**DATE SAMPLED: 4/13/2020**

**TIME SAMPLED: N/A:**

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/15/20
Copper, EPA 200.7	<0.010	mg/l	1.3	4/16/20

< = less than, not detected. Method Detection Limits and Reporting Limits available at [www.gsllabs.com/certnjdep.html](http://www.gsllabs.com/certnjdep.html)

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*  
 413064

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.  
 Main Lab certified by NJDEP #20044-TN1, NY Dept. of Health #11550 and PADEP #68-03680.

# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
Email: info@gslabs.com  
Internet: www.gslabs.com

Main Lab  
410 Hillside Avenue  
Hillside, New Jersey 07205  
NJDEP Lab Cert. #20044

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director  
Jordan B. Klein, B.A., Exec. Vice President  
Sharon Ercoliani, B.A., Laboratory Manager

## REPORT OF ANALYSIS

Jersey Shore Lab  
54 Main Street  
Waretown, New Jersey 08758  
NJDEP Lab Cert. #15037  
REPORT # 400413003.0  
CLIENT # ARC13

TO: The ARC of Union County  
70 Diamond Road

DATE SUBMITTED: 4/13/2020

Springfield NJ 07081  
ATT: Armando Jimenez

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID: FIRST DRAW

SAMPLE LOCATION: CLASS ROOM # 7 - ARC KOHLER SCHOOL, 1137 GLOBE AVE.,  
MOUNTAINSIDE, NJ 07092

DATE SAMPLED: 4/13/2020

TIME SAMPLED: 08:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/15/20
Copper, EPA 200.7	0.041	mg/l	1.3	4/16/20

< = less than, not detected. Method Detection Limits and Reporting Limits available at [www.gslabs.com/certnjdep.html](http://www.gslabs.com/certnjdep.html)  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

413064

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.  
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
Email: [info@gsllabs.com](mailto:info@gsllabs.com)  
Internet: [www.gsllabs.com](http://www.gsllabs.com)

Main Lab  
410 Hillside Avenue  
Hillside, New Jersey 07205  
NJDEP Lab Cert. #20044

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director  
Jordan B. Klein, B.A., Exec. Vice President  
Sharon Ercoliani, B.A., Laboratory Manager

## REPORT OF ANALYSIS

Jersey Shore Lab  
54 Main Street  
Waretown, New Jersey 08758  
NJDEP Lab Cert. #15037  
REPORT # 400413004.0

TO: The ARC of Union County  
70 Diamond Road

CLIENT # ARC13  
DATE SUBMITTED: 4/13/2020

Springfield

NJ 07081

ATT: Armando Jimenez

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID: FIRST DRAW

SAMPLE LOCATION: CLASS ROOM # 2 - ARC KOHLER SCHOOL, 1137 GLOBE AVE.,  
MOUNTAINSIDE, NJ 07092

DATE SAMPLED: 4/13/2020

TIME SAMPLED: 08:46

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/15/20
Copper, EPA 200.7	1.15	mg/l	1.3	4/16/20

< = less than, not detected. Method Detection Limits and Reporting Limits available at [www.gsllabs.com/certnjdpe.html](http://www.gsllabs.com/certnjdpe.html)

MCL = Maximum Contaminant Level allowed by State and Federal regulations.



413064

# Garden State Laboratories, Inc.

*Bacteriological and Chemical Testing*



Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director  
Jordan B. Klein, B.A., Exec. Vice President  
Sharon Ercoliani, B.A., Laboratory Manager

Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
Email: info@gsllabs.com  
Internet: www.gsllabs.com

Main Lab  
410 Hillside Avenue  
Hillside, New Jersey 07205  
NJDEP Lab Cert. #20044

Jersey Shore Lab  
54 Main Street  
Waretown, New Jersey 08758  
NJDEP Lab Cert. #15037  
**REPORT # 400413005.0**

**CLIENT # ARC13**  
**DATE SUBMITTED: 4/13/2020**

## REPORT OF ANALYSIS

**TO: The ARC of Union County**  
**70 Diamond Road**

**Springfield NJ 07081**  
**ATT: Armando Jimenez**

**SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE**

**SAMPLE ID: FIRST DRAW**

**SAMPLE LOCATION: CLASS ROOM # 1 - ARC KOHLER SCHOOL, 1137 GLOBE AVE.,  
MOUNTAINSIDE, NJ 07092**

**DATE SAMPLED: 4/13/2020**

**TIME SAMPLED: 09:01**

<b>ANALYSIS</b>	<b>RESULT</b>	<b>UNITS</b>	<b>MCL</b>	<b>DATE ANALYZED</b>
Lead, EPA 200.9	<0.001	mg/l	0.015	4/15/20
Copper, EPA 200.7	0.848	mg/l	1.3	4/16/20

< = less than, not detected. Method Detection Limits and Reporting Limits available at [www.gsllabs.com/certnjdep.html](http://www.gsllabs.com/certnjdep.html)  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

413064

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.  
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing



Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
Email: [info@gslabs.com](mailto:info@gslabs.com)  
Internet: [www.gslabs.com](http://www.gslabs.com)

Main Lab  
410 Hillside Avenue  
Hillside, New Jersey 07205  
NJDEP Lab Cert. #20044

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director  
Jordan B. Klein, B.A., Exec. Vice President  
Sharon Ercoliani, B.A., Laboratory Manager

## REPORT OF ANALYSIS

Jersey Shore Lab  
54 Main Street  
Waretown, New Jersey 08758  
NJDEP Lab Cert. #15037  
REPORT # 400413006.0

TO: The ARC of Union County  
70 Diamond Road

CLIENT # ARC13  
DATE SUBMITTED: 4/13/2020

Springfield

NJ 07081

ATT: Armando Jimenez

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE

SAMPLE ID: FIRST DRAW

SAMPLE LOCATION: CLASS ROOM COMP/TEC - ARC KOHLER SCHOOL, 1137 GLOBE  
AVE., MOUNTAINSIDE, NJ 07092

DATE SAMPLED: 4/13/2020

TIME SAMPLED: 09:17

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/15/20
Copper, EPA 200.7	0.057	mg/l	1.3	4/16/20

< = less than, not detected. Method Detection Limits and Reporting Limits available at [www.gslabs.com/certnjdep.html](http://www.gslabs.com/certnjdep.html)

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Handwritten signature of Harvey Klein*

413064

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.  
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing



Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director  
 Jordan B. Klein, B.A., Exec. Vice President  
 Sharon Ercoliani, B.A., Laboratory Manager

Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 Email: info@gslabs.com  
 Internet: www.gslabs.com

Main Lab  
 410 Hillside Avenue  
 Hillside, New Jersey 07205  
 NJDEP Lab Cert. #20044

Jersey Shore Lab  
 54 Main Street  
 Waretown, New Jersey 08758  
 NJDEP Lab Cert. #15037  
**REPORT # 400413007.0**

## REPORT OF ANALYSIS

**TO: The ARC of Union County**  
 70 Diamond Road

**CLIENT # ARC13**  
**DATE SUBMITTED: 4/13/2020**

Springfield

NJ 07081

ATT: Armando Jimenez

**SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE**

**SAMPLE ID: FIRST DRAW**

**SAMPLE LOCATION: NURSES ROOM & LIBRARY HALLWAY - ARC KOHLER SCHOOL,  
 1137 GLOBE AVE., MOUNTAINSIDE, NJ 07092**

**DATE SAMPLED: 4/13/2020**

**TIME SAMPLED: 09:37**

<b>ANALYSIS</b>	<b>RESULT</b>	<b>UNITS</b>	<b>MCL</b>	<b>DATE ANALYZED</b>
Lead, EPA 200.9	<0.001	mg/l	0.015	4/15/20
Copper, EPA 200.7	0.056	mg/l	1.3	4/16/20

< = less than, not detected. Method Detection Limits and Reporting Limits available at [www.gslabs.com/certnjdep.html](http://www.gslabs.com/certnjdep.html)  
 MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Harvey Klein*

413064

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.  
 Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing



Toll Free 800-273-8901  
 Telephone 908-688-8900  
 Fax 908-688-8966  
 Email: info@gslabs.com  
 Internet: www.gslabs.com

Main Lab  
 410 Hillside Avenue  
 Hillside, New Jersey 07205  
 NJDEP Lab Cert. #20044

Mathew Klein, M.S., Founder (1916-1996)  
 Harvey Klein, M.S., Laboratory Director  
 Jordan B. Klein, B.A., Exec. Vice President  
 Sharon Ercoliani, B.A., Laboratory Manager

**REPORT OF ANALYSIS**

Jersey Shore Lab  
 54 Main Street  
 Waretown, New Jersey 08758  
 NJDEP Lab Cert. #15037

**REPORT # 400413008.0**

**CLIENT # ARC13**

**DATE SUBMITTED: 4/13/2020**

**TO: The ARC of Union County**  
**70 Diamond Road**

Springfield

NJ 07081

ATT: Armando Jimenez

**SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE**

**SAMPLE ID: FIRST DRAW**

**SAMPLE LOCATION: KITCHEN - ARC KOHLER SCHOOL, 1137 GLOBE AVE.,  
 MOUNTAINSIDE, NJ 07092**

**DATE SAMPLED: 4/13/2020**

**TIME SAMPLED: 09:53**

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/15/20
Copper, EPA 200.7	0.053	mg/l	1.3	4/16/20

< = less than, not detected. Method Detection Limits and Reporting Limits available at [www.gslabs.com/certnjdep.html](http://www.gslabs.com/certnjdep.html)

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

*Handwritten signature: Harvey Klein*

413064

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.  
 Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

